



Publication Year	2021
Acceptance in OA	2023-12-29T14:50:34Z
Title	NI-DPU ASW v1.3.8 Test Plan and Test Report
Authors	MEDINACELI VILLEGAS, Eduardo, Zadeja, Anton, SIRIGNANO, CHIARA
Handle	http://hdl.handle.net/20.500.12386/34503



NI-DPU ASW v1.3.8 Test Plan and Test Report

Ref : EUCL-IBO-TN-7-037
Issue : 1.0
Date: 24/11/2021
Page: 1/9

TITLE:	NI-DPU ASW v1.3.8 Test Plan and Test Report		
Date:	24/11/2020	Issue:	1.0
Reference:	EUCL-IBO-TN-7-037		
Custodian:	Eduardo Medinaceli		

Authors:	Function:	Date:	Signature:
E. Medinaceli	DPU-ASW manager		
A. Zadeja	TASI operations expert		
C. Sirignano	NISP operations expert		
Approved by:	Function:	Date:	Signature:
S. Dusini			
Authorised by:	Function:	Date:	Signature:
L. Valenziano			

Change Log

Issue	Date	Page	Description Of Change
1.0	24/11/2021	All	First issue

Table of Contents

1.	Purpose and Scope	3
2.	Reference Documents	3
3.	Acronyms.....	3
4.	Validation test dedicated to v1.3.8 of DPU ASW	4
4.1	Software version.....	4
4.2	DPU-ASWv1.3.8 Validation Test Plan	4
4.3	Test Results.....	5
4.4	Results summary	8
4.5	Issues found.....	9
5.	Attachments.....	9



NI-DPU ASW v1.3.8 Test Plan and Test Report

Ref : EUCL-IBO-TN-7-037
Issue : 1.0
Date: 24/11/2021
Page: 3/9

1. Purpose and Scope

The objective of this document is to provide the test plan carried out on v1.3.8 of the DPU ASW and to report the test results. All tests were done at system level.

This document is focused on the ASW test phase carried out on DPU AVM at TAS premises in Turin after its qualification to validate the applicative before installing it on DPU FM units.

2. Reference Documents

RD	Title / Author	Document Reference	Issue	Date
0	NISP Acronyms List	EUCL-IAP-LI-1-001	2.0	04/05/2013
1	NI-DPU ASW post QAR Configuration Control – Issues/SPR	EUCL-IBO-TN-7-028	1.1	16/11/2021
2	NI-DPU ASW v1.3.8 – Software Release Notes	EUCL-IBO-TN-7-036	1.0	16/11/2021
3	NI-DPU ASW: blocking communication issue between SCE and DCU	EUCL-IBO-NCR-7-030	1.0	28/09/2021

3. Acronyms

See RD0



NI-DPU ASW v1.3.8 Test Plan and Test Report

Ref : EUCL-IBO-TN-7-037
Issue : 1.0
Date: 24/11/2021
Page: 4/9

4. Validation test dedicated to v1.3.8 of DPU ASW

Date and Location

From 10/11/2021 till 12/11/2021 in TAS-I Torino

Tests performed by Eduardo Medinaceli – INAF OAS (on site)
Anton Zadeja TASI (on site)
Chiara Sirignano INFN – Pd (remote)

- Setup at TASI used for the tests was a rearrangement of the SOVT1 setup: DPU1 (DPU-EM) using only DCU1 and DPU2 (DPU-EQM) equipped with 8 x SCEs (SCE7 was excluded from the setup because the detection chain was not stable).
- The list of SW interventions on DPU-ASW v1.3.7 implemented in DPU-ASWv1.38 are detailed in RD-1, and RD-2.

4.1 Software version

The SW configuration used to perform the tests is as follow:

ICU ASW v 1.9 - DPU ASW 1.3.8 – MIB TA2_3-17 (that contains NISP_3-67).

4.2 DPU-ASWv1.3.8 Validation Test Plan

pre-requirement:

- Load on DPU's E2PROM image2 DPU-ASWv1.3.8

<u>Sequence</u>	<u>Description</u>	<u>Execution Time Forecast</u>
power up:		
1. SST_01, SST_03	(ICU on)	(15 min)
2. SST_04	(DPU/DCU on)	(3 min) (1 DPU – 1DCU)
exposures:		
3. SST_05	(exposure preparation)	(1 min)
4. SST_11	(SIM exposure)	(5 min)
5. SST_12	(grounded exposure)	(5 min) (+ optional K-sequence)
6. SST_13_01,_02, _03,_04,_05	(engineering modes and calibrations)	(5*5 min)
Dither abort:		
7. send_dither_abort	(Dither abort)	(5 min)
fdirs:		
8. FFT20	(DPU FDIRs)	(15 min)
	covers case (1) ALARM_DCU28V, and DCUASW_ALLDCUOFF	
9. Program a Dither with 2 Exp and executed only one	cover case (2) WCD_WD_PROC_EXPIRED*	



NI-DPU ASW v1.3.8 Test Plan and Test Report

Ref : EUCL-IBO-TN-7-037
Issue : 1.0
Date: 24/11/2021
Page: 6/9

2006-2024 11-11T09:43:43.434

TMHIST [ccs-11_21_11T07_37_09_zadeja-ccs-w1_r1_EW317]

2021-11-11T09:09:40.434

GO

⏪

⏩

⏴

⏵

⏶

⏷

LIVE

?

Packet ID	SPID	Name	APID	SSC	T	ST	Generation Time	Reception Time	P11	P12	Source	Description	
97394	0	300502342	N_DPU1LowErr	1312	2140	5	2	1970-01-01T01:28:30.741	2021-11-11T09:11:42.424	342	0	tmic-dfe	Errors triggered by DPUW2 that do not require an FDIR
97345	0	300502342	N_DPU1LowErr	1312	2138	5	2	1970-01-01T01:28:29.741	2021-11-11T09:11:41.959	342	0	tmic-dfe	Errors triggered by DPUW2 that do not require an FDIR
97025	0	300502342	N_DPU1LowErr	1312	2127	5	2	1970-01-01T01:28:12.741	2021-11-11T09:11:23.956	342	0	tmic-dfe	Errors triggered by DPUW2 that do not require an FDIR
97019	0	300502342	N_DPU1LowErr	1312	2125	5	2	1970-01-01T01:28:11.741	2021-11-11T09:11:23.952	342	0	tmic-dfe	Errors triggered by DPUW2 that do not require an FDIR
96727	0	300502342	N_DPU1LowErr	1312	2114	5	2	1970-01-01T01:27:55.740	2021-11-11T09:11:07.909	342	0	tmic-dfe	Errors triggered by DPUW2 that do not require an FDIR
96681	0	300502342	N_DPU1LowErr	1312	2111	5	2	1970-01-01T01:27:54.740	2021-11-11T09:11:06.223	342	0	tmic-dfe	Errors triggered by DPUW2 that do not require an FDIR
96460	0	300502342	N_DPU1LowErr	1312	2104	5	2	1970-01-01T01:27:42.738	2021-11-11T09:10:53.862	342	0	tmic-dfe	Errors triggered by DPUW2 that do not require an FDIR
96442	0	300502342	N_DPU1LowErr	1312	2102	5	2	1970-01-01T01:27:41.738	2021-11-11T09:10:52.873	342	0	tmic-dfe	Errors triggered by DPUW2 that do not require an FDIR
95105	0	300501328	N_ICUStateSta	1312	2053	5	1	1970-01-01T01:26:30.067	2021-11-11T09:09:41.424	328	0	tmic-dfe	ICU event - SAFE state notification
95104	0	300503344	N_DPU1MedErr	1312	2054	5	3	1970-01-01T01:26:30.067	2021-11-11T09:09:41.424	344	0	tmic-dfe	Errors triggered by DPUW1 that do not require an FDIR
95088	0	300502340	N_DPU1LowErr	1312	2051	5	2	1970-01-01T01:26:28.066	2021-11-11T09:09:40.434	340	0	tmic-dfe	Errors triggered by DPUW1 that do not require an FDIR
95088	0	300502340	N_DPU1LowErr	1312	2049	5	2	1970-01-01T01:26:27.898	2021-11-11T09:09:39.034	340	0	tmic-dfe	Errors triggered by DPUW1 that do not require an FDIR
48077	0	300501388	N_DPU1TransRp	1312	400	5	1	1970-01-01T00:44:11.088	2021-11-11T08:27:22.239	388	0	tmic-dfe	Report after DPU SW commanded transition

Properties

Parameters

ID	Info	Raw	Eng
NIST8500	OK	340	DPU1_LowSevErr
NIST8542	OK	5189718414307	1970-01-01T01:26:28.718
NIST8543	OK	0	"NO VAL"
NIST8544	OK	0	"NO VAL"
NIST8554	OK	0	"NO VAL"
NIST8555	OK	1	low_criticity
NIST8556	OK	178913281	ALARM_THRSCIE
NIST8557	OK	1	"NO VAL"
NIST8525	OK	1	"NO VAL"

	00	01	02	03	04	05	06	07	08	09	0A	0B	0C	0D	0E	0F
0000	00	20	C8	03	00	25	10	05	02	00	00	00	14	44	B2	C9
0010	01	54	00	00	14	42	B7	EA	00	00	00	00	00	00	00	00
0020	00	01	0A	AA	00	01	00	01	00	01	2D	85				

N_DPU1LowErr: Errors triggered by DPUW1 that do not require an FDIR

Show

☒ Details

☐ Filters

☐ Settings

Each one of the FDIRs shown before were triggered for all the detectors resulting on NISP system FDIR:

TMHIST (33591) 2021-11-11T09:12:32.284 N_DPU2MedErr

2021-11-11T09:12:32.284

GO

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

PM

AM

Instead, errors injected with sequence 9 programming a Dither for which not all the exposure commands were send, the watchdog systems were successfully triggered but the OBT contained in the DPU error table were not correctly retrieved.

This didn't produce a limitation for the NISP recovery action because the telemetry table send by the ICU reported correctly the OBT. This issue will be discussed in a separate document.



NI-DPU ASW v1.3.8 Test Plan and Test Report

Ref : EUCL-IBO-TN-7-037
Issue : 1.0
Date: 24/11/2021
Page: 7/9

Watchdog End of Exposure

TMHIST [ext-srv3] 2021_11_10T07_57_20_xadeja_ccs-w11_RT_EW317

2021-11-10T14:02:11.350

GO

⏪

⏴

⏵

⏩

LIVE

Packet ID	SPID	Name	APID	SSC	T	ST	Generation Time	Reception Time	P11	P12	Source	Description	
573555	1	300503345	N_DPU2MedErr	1312	7389	5	3	1970-01-01T07:48:49.068	2021-11-10T16:59:23.784	345	0	Intc-dfe	Errors triggered by DPUK2 that do require an FDIR
573554	1	300503344	N_DPU1MedErr	1312	7376	5	3	1970-01-01T07:48:31.068	2021-11-10T16:59:23.784	344	0	Intc-dfe	Errors triggered by DPUK1 that do require an FDIR
573550	1	300503345	N_DPU2MedErr	1312	3687	5	3	1970-01-01T06:15:29.069	2021-11-10T16:59:23.784	345	0	Intc-dfe	Errors triggered by DPUK2 that do require an FDIR
573549	1	300503344	N_DPU1MedErr	1312	3161	5	3	1970-01-01T06:02:15.069	2021-11-10T16:59:23.783	344	0	Intc-dfe	Errors triggered by DPUK1 that do require an FDIR
573548	1	300503345	N_DPU2MedErr	1312	2259	5	3	1970-01-01T05:39:17.069	2021-11-10T16:59:23.783	345	0	Intc-dfe	Errors triggered by DPUK2 that do require an FDIR
521975	0	300503345	N_DPU2MedErr	1312	7389	5	3	1970-01-01T07:48:49.068	2021-11-10T16:11:43.390	345	0	Intc-dfe	Errors triggered by DPUK2 that do require an FDIR
521641	0	300503344	N_DPU1MedErr	1312	7376	5	3	1970-01-01T07:48:31.068	2021-11-10T16:11:25.655	344	0	Intc-dfe	Errors triggered by DPUK1 that do require an FDIR
418243	0	300503345	N_DPU2MedErr	1312	3687	5	3	1970-01-01T06:15:29.069	2021-11-10T14:38:23.529	345	0	Intc-dfe	Errors triggered by DPUK2 that do require an FDIR
403688	0	300503344	N_DPU1MedErr	1312	3161	5	3	1970-01-01T06:02:15.069	2021-11-10T14:25:09.621	344	0	Intc-dfe	Errors triggered by DPUK1 that do require an FDIR
375991	0	300503345	N_DPU2MedErr	1312	2259	5	3	1970-01-01T05:39:17.068	2021-11-10T14:02:11.350	345	0	Intc-dfe	Errors triggered by DPUK2 that do require an FDIR

Properties

Parameters

ID	Info	Raw	Eng
NIST8500	OK	345	DPU2_MedSevErr
NIST8542	OK	0	1970-01-01T00:00:00.000
NIST8543	OK	0	"NO VAL"
NIST8544	OK	0	"NO VAL"
NIST8554	OK	0	"NO VAL"
NIST8556	OK	2	Med_Criticality
NIST8555	OK	97320961	WCD_WCDEXP_EXP
NIST8557	OK	1	"NO VAL"
NIST8525	OK	1	"NO VAL"

00	01	02	03	04	05	06	07	08	09	0A	0B	0C	0D	0E	0F
0000	00	20	C8	D3	00	25	10	05	03	00	00	00	4F	85	11
0010	01	59	00	00	00	00	00	00	00	00	00	00	00	00	00
0020	00	02	05	CD	00	01	00	01	00	01	49	69	00	00	00

N_DPU2MedErr: Errors triggered by DPUK2 that do require an FDIR

ShowDetailsFiltersSettings

Watchdog end of Dither

TMHIST [ext-srv3] 2021_11_10T07_57_20_xadeja_ccs-w11_RT_EW317

2021-11-10T14:25:09.621 GO [] [

All 290 errors injected (generated) during the current test session were analysed (including the ones originated from the non-correct setup leading to the exclusion of DPU2-SCE7). Besides for errors coming from the Watchdog system, all the others have correctly saved the OBT in the DPU ERROR_TAB as well as all the other fields on the table; for example, errors ASW_FOCALPLANEOFF and SCE_EHSK (time initialized to 01/01/1970):

DPU-ASW OBT coarse	DPU-ASW OBT fine	Sub system	CMD/ Function ID	Criticality	ASW error code (error name)	Multiplicity	OBT DPU-ASW_ERROR_TAB
00006dce	42b7	0000 (not used)	00eb	0002	0x0a5703f2 (ASW_FOCALPLANEOFF)	0001	01/01/1970 07:48:31
00004dcd	31e1	0006 (DCU7)	00e7	0001	0x073d0005 (SCE_EHSK)	0001	01/01/1970 05:31:57

in the table the driver error (errno) is not shown because is not trapped in any of these two cases.

The comparison of the ICU-OBT and the DPU-OBT is shown in Figure 1, where events from the watchdog systems were excluded:




Figure 1, NISP events, OBT comparison between ICU and DPU; the linear fit shows the perfect correlation between these two times.

4.4 Results summary

In the following table are summarized the results of the validation procedures where general features of NISP were tested, **the results are as expected for all cases besides errors generated by the watchdog systems (test ID = 9).**

Test procedure Id	Description	Results
1	ICU ON pre-requirement	OK
2	DPU/DCU power ON	OK
3	Exposure preparation	OK
4	Simulated exposure	OK
5	Grounded exposure (nominal cycle, using Zero Bias)	OK
6	Engineering modes: IPC, KTC, Debug, Raw mode, Compression Verification	OK
7	Dither abort	OK
8	Error injection: ALARM_DCU28V, ALARM_THRSCE, DCUASW_ALLDCUOFF	OK
9	Errors from watchdog systems: WCD_WD_EXP_EXPIRED, WCD_WD_PROC_EXPIRED	NOT OK
10	- CPU_RESET with focal plane OFF - CPU_RESET with focal plane ON	OK
11	ASW_FUNC_TURNOFFFOCALPLANE	OK
12	DPU/DCU power OFF	OK
13	ICU OFF	OK



NI-DPU ASW v1.3.8 Test Plan and Test Report

Ref : EUCL-IBO-TN-7-037
Issue : 1.0
Date: 24/11/2021
Page: 9/9

Specific tests done at LAM using a dedicated setup used to investigate the new DCU_ERROR_REG management are document in EUCL-IBO-TN-7-028-NI-DPU-ASW post QAR Configuration Control Issues/SPR v1.1 [RD-1].

Attached to this document can be found the slides of the dedicated test done at LAM with a dedicated setup (description included) used in the resolution of the 'DCU-SCE communication issue' - RD-3.

4.5 Issues found

- (1) related to test ID = 9: failed to get correct time tag for errors from watchdog systems: WCD_WD_PROC_EXPIRED and WCD_WD_EXP_EXPIRED.
Two out of 181 error injection entries (1.3%) found during the validation tests.
- (2) related to test ID = 10: FFT22/CONT_20_BOTH_DPU_CPU_RESET (DPU reboot) reboot executed correctly, restore of nominal operations FAILED because the SCE's flag SCE_IDLE was not set and SCE commanding was therefore not enabled.

Limitations on normal operations

- (1) none for NISP nominal operations because no functionalities are compromised including error injection (all error parameters are OK), and timing. The OBT of the event associated to the DPU error is correctly reported.
- (2) procedural limitation during the recovery action applied to the CPU reset is needed, in the current implementation the flag SCE_IDLE is not set, and this flag can be rise by applying command CPU_DABT (Dither Abort).

Both minor limitations will be discussed in a dedicated NRB.

5. Attachments

In attachment are the following presentations:

- DCUerrorsStrategy.pdf
- DPU-ASW_ProveOfConcept_FIFOerrors_update.pdf
- 1stLAMtestssession.pdf
- 2ndTestSession@LAM.pdf